



Development of Solar Power Systems for ITS

Adam Wellner, MnDOT District 6

Your Destination...Our Priority




Presentation Outline

- ▶ Background
- ▶ Design Requirements
- ▶ Solar Design Process / Procedures
 - Battery Bank
 - Power Array
 - Environmental Factors
 - Other Considerations
- ▶ Challenges
- ▶ Cost Analysis
- ▶ Lessons Learned & Conclusions



Project Background

- ▶ Second phase installation of ITS devices along I-35 near Faribault MN
- ▶ Primarily rural area
- ▶ 7 of 19 locations with no viable SOP







Use of renewable energy for ITS (in Minnesota)

- ▶ DMS system powered by solar was deployed
- ▶ Camera deployed using wind power
 - Later retrofitted to add solar panels to improve reliability – has history of maintenance problems



Design Requirements

- ▶ Minimize down time
- ▶ Minimize maintenance requirements
- ▶ Environmental factors
 - Solar Insolation
 - Temperature
- ▶ Use same devices as phase-I (prior project)
- ▶ Cost
 - Operational / Maintenance
 - Installation



Design Process

Determine Specific Design Requirements



Battery Bank Design



Solar Array Design



Electrical System Design



Shade and Site Design



Power Demand



PTZ Camera
Power Requirements
Volts: 24 VDC
Watts: 51 W




Fiber Optic Switch
Power Requirements
Volts: 10.5–60 VDC
Watts: 24 W / 15 W

Total Power Demand (Average)
Volts: 24 VDC
Watts: 66 W
Amps: 2.75 A



Climate Data

- ▶ Temperature
- ▶ Insolation
- ▶ Sun Path



- ▶ *Solar Radiation Data Manual for Flat-Plate and Concentrating Collectors (Red Book)*
- ▶ State Climatologist
- ▶ University of Oregon Solar Radiation Monitoring Laboratory




Rochester, MN

WBAN NO. 14925

LATITUDE: 43.92° N
LONGITUDE: 92.50° W
ELEVATION: 402 meters
MEAN PRESSURE: 968 millibars

STATION TYPE: Secondary



Solar Radiation for Flat-Plate Collectors Facing South at a Fixed Tilt (kWh/m²/day), Uncertainty ±9%

| Tilt (°) | | Jan | Feb | Mar | Apr | May | June | July | Aug | Sept | Oct | Nov | Dec | Year |
|--------------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| 0 | Average | 1.8 | 2.7 | 3.7 | 4.6 | 5.6 | 6.2 | 6.2 | 5.3 | 4.0 | 2.8 | 1.7 | 1.4 | 3.8 |
| | Min/Max | 1.5/2.1 | 2.3/3.0 | 3.0/4.3 | 3.9/5.5 | 4.8/6.5 | 5.4/7.3 | 5.3/7.0 | 4.5/6.0 | 3.3/4.7 | 2.3/3.3 | 1.4/2.0 | 1.2/1.7 | 3.7/4.1 |
| Latitude -15 | Average | 2.9 | 3.9 | 4.6 | 5.1 | 5.7 | 6.0 | 6.2 | 5.7 | 4.8 | 3.8 | 2.6 | 2.3 | 4.5 |
| | Min/Max | 2.2/3.6 | 2.9/4.5 | 3.5/5.6 | 4.1/6.3 | 4.9/6.6 | 5.3/7.1 | 5.2/7.1 | 4.7/6.5 | 3.6/5.8 | 3.0/4.7 | 1.7/3.2 | 1.8/2.9 | 4.1/4.9 |
| Latitude | Average | 3.3 | 4.2 | 4.7 | 4.9 | 5.3 | 5.5 | 5.7 | 5.5 | 4.8 | 4.1 | 2.8 | 2.6 | 4.5 |
| | Min/Max | 2.4/4.2 | 3.1/5.0 | 3.5/5.9 | 4.0/6.2 | 4.6/6.2 | 4.8/6.6 | 4.8/6.6 | 4.4/6.3 | 3.5/5.9 | 3.1/5.1 | 1.8/3.6 | 2.0/3.4 | 4.1/4.9 |
| Latitude +15 | Average | 3.6 | 4.4 | 4.7 | 4.6 | 4.7 | 4.8 | 5.0 | 4.9 | 4.6 | 4.1 | 2.9 | 2.8 | 4.3 |
| | Min/Max | 2.5/4.5 | 3.2/5.2 | 3.4/6.0 | 3.8/5.8 | 4.1/5.4 | 4.2/5.6 | 4.2/5.7 | 4.0/5.7 | 3.3/5.7 | 3.0/5.1 | 1.8/3.8 | 2.2/3.7 | 3.9/4.6 |
| 90 | Average | 3.5 | 4.1 | 3.9 | 3.2 | 2.8 | 2.7 | 2.9 | 3.2 | 3.4 | 3.4 | 2.7 | 2.7 | 3.2 |
| | Min/Max | 2.4/4.4 | 2.9/4.9 | 2.7/5.3 | 2.7/3.9 | 2.6/3.2 | 2.5/3.1 | 2.5/3.2 | 2.6/3.6 | 2.4/4.2 | 2.5/4.3 | 1.5/3.5 | 2.1/3.7 | 2.9/3.5 |

Solar Radiation for 1-Axis Tracking Flat-Plate Collectors with a North-South Axis (kWh/m²/day), Uncertainty ±9%

| Axis Tilt (°) | | Jan | Feb | Mar | Apr | May | June | July | Aug | Sept | Oct | Nov | Dec | Year |
|---------------|---------|---------|---------|---------|---------|---------|----------|---------|---------|---------|---------|---------|---------|---------|
| 0 | Average | 2.7 | 3.9 | 5.0 | 6.1 | 7.3 | 8.0 | 8.2 | 7.1 | 5.5 | 4.0 | 2.4 | 2.0 | 5.2 |
| | Min/Max | 1.9/3.3 | 2.8/4.5 | 3.6/6.3 | 4.7/7.7 | 5.8/8.9 | 6.8/9.9 | 6.7/9.6 | 5.7/8.3 | 3.9/6.9 | 2.9/4.9 | 1.5/3.0 | 1.6/2.5 | 4.8/5.8 |
| Latitude -15 | Average | 3.5 | 4.8 | 5.7 | 6.5 | 7.5 | 8.0 | 8.3 | 7.5 | 6.1 | 4.7 | 3.0 | 2.7 | 5.7 |
| | Min/Max | 2.5/4.4 | 3.3/5.7 | 4.0/7.3 | 5.0/8.4 | 5.9/9.1 | 6.8/10.0 | 6.7/9.7 | 5.9/8.8 | 4.2/7.7 | 3.4/6.0 | 1.8/3.9 | 2.1/3.5 | 5.2/6.4 |
| Latitude | Average | 3.8 | 5.1 | 5.8 | 6.4 | 7.2 | 7.7 | 8.0 | 7.4 | 6.2 | 4.9 | 3.2 | 2.9 | 5.7 |
| | Min/Max | 2.7/4.9 | 3.5/6.1 | 4.1/7.6 | 4.9/8.3 | 5.7/8.9 | 6.5/9.6 | 6.5/9.4 | 5.7/8.7 | 4.2/7.8 | 3.5/6.3 | 1.9/4.3 | 2.3/3.9 | 5.2/6.4 |
| Latitude +15 | Average | 4.0 | 5.2 | 5.8 | 6.1 | 6.8 | 7.2 | 7.5 | 7.0 | 6.0 | 5.0 | 3.3 | 3.1 | 5.6 |
| | Min/Max | 2.8/5.2 | 3.5/6.2 | 4.0/7.6 | 4.7/8.0 | 5.3/8.4 | 6.1/9.0 | 6.1/8.8 | 5.4/8.3 | 4.0/7.6 | 3.5/6.3 | 1.9/4.4 | 2.4/4.1 | 5.0/6.3 |

Solar Radiation for 2-Axis Tracking Flat-Plate Collectors (kWh/m²/day), Uncertainty ±9%

| Tracker | | Jan | Feb | Mar | Apr | May | June | July | Aug | Sept | Oct | Nov | Dec | Year |
|---------|---------|---------|---------|---------|---------|---------|----------|---------|---------|---------|---------|---------|---------|---------|
| 2-Axis | Average | 4.1 | 5.2 | 5.8 | 6.5 | 7.6 | 8.2 | 8.5 | 7.6 | 6.2 | 5.0 | 3.3 | 3.1 | 5.9 |
| | Min/Max | 2.8/5.2 | 3.6/6.2 | 4.1/7.6 | 5.0/8.4 | 6.0/9.3 | 7.0/10.3 | 6.9/9.9 | 5.9/8.9 | 4.2/7.8 | 3.6/6.3 | 1.9/4.4 | 2.4/4.2 | 5.3/6.6 |

Direct Beam Solar Radiation for Concentrating Collectors (kWh/m²/day), Uncertainty ±8%

| Tracker | | Jan | Feb | Mar | Apr | May | June | July | Aug | Sept | Oct | Nov | Dec | Year |
|---------------------------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| 1-Axis, E-W Horiz Axis | Average | 2.2 | 2.6 | 2.6 | 2.8 | 3.4 | 3.7 | 3.9 | 3.5 | 2.9 | 2.6 | 1.8 | 1.7 | 2.8 |
| | Min/Max | 1.2/3.1 | 1.2/3.5 | 1.4/3.6 | 1.6/4.4 | 2.2/4.7 | 2.6/5.4 | 2.6/5.0 | 2.2/4.5 | 1.4/4.2 | 1.7/3.8 | 0.6/2.7 | 1.1/2.4 | 2.3/3.4 |
| 1-Axis, N-S Horiz Axis | Average | 1.5 | 2.2 | 2.8 | 3.6 | 4.4 | 4.9 | 5.2 | 4.6 | 3.5 | 2.5 | 1.3 | 1.0 | 3.1 |
| | Min/Max | 0.8/2.1 | 0.9/3.0 | 1.5/3.9 | 2.0/5.5 | 2.8/6.3 | 3.6/7.1 | 3.6/6.6 | 3.0/5.9 | 1.7/5.0 | 1.5/3.6 | 0.4/2.0 | 0.7/1.5 | 2.6/3.8 |
| 1-Axis, N-S Tilt+Latitude | Average | 2.4 | 3.1 | 3.4 | 3.9 | 4.4 | 4.7 | 5.0 | 4.7 | 4.0 | 3.3 | 2.0 | 1.8 | 3.6 |
| | Min/Max | 1.2/3.3 | 1.4/4.3 | 1.8/4.8 | 2.2/6.0 | 2.8/6.2 | 3.4/6.8 | 3.5/6.4 | 3.1/6.1 | 2.0/5.7 | 2.1/4.7 | 0.6/3.0 | 1.1/2.5 | 2.9/4.3 |
| 2-Axis | Average | 2.6 | 3.2 | 3.4 | 3.9 | 4.7 | 5.1 | 5.4 | 4.9 | 4.0 | 3.4 | 2.1 | 1.9 | 3.7 |
| | Min/Max | 1.3/3.5 | 1.4/4.4 | 1.8/4.8 | 2.2/6.1 | 3.0/6.5 | 3.7/7.4 | 3.7/6.8 | 3.2/6.3 | 2.0/5.8 | 2.1/4.8 | 0.7/3.1 | 1.2/2.8 | 3.1/4.5 |

Average Climatic Conditions

| Element | Jan | Feb | Mar | Apr | May | June | July | Aug | Sept | Oct | Nov | Dec | Year |
|-----------------------|-------|-------|-------|-------|------|------|------|------|------|-------|-------|-------|-------|
| Temperature (°C) | -11.4 | -8.3 | -1.2 | 7.2 | 13.8 | 19.2 | 21.6 | 20.1 | 15.1 | 8.8 | 0.3 | -8.2 | 6.4 |
| Daily Minimum Temp | -16.3 | -13.3 | -5.9 | 1.4 | 7.5 | 12.9 | 15.6 | 14.2 | 9.2 | 3.1 | -4.2 | -12.6 | 0.9 |
| Daily Maximum Temp | -6.6 | -3.3 | 3.4 | 12.9 | 20.1 | 25.4 | 27.7 | 26.0 | 21.0 | 14.6 | 4.9 | -3.9 | 11.8 |
| Record Minimum Temp | -35.6 | -33.9 | -35.0 | -15.0 | -6.1 | 1.7 | 5.6 | 2.8 | -5.0 | -11.7 | -28.9 | -36.1 | -36.1 |
| Record Maximum Temp | 12.8 | 17.2 | 26.1 | 32.8 | 33.3 | 38.3 | 38.9 | 37.2 | 35.0 | 31.1 | 22.8 | 16.7 | 38.9 |
| HDD, Base 18.3°C | 922 | 745 | 606 | 335 | 157 | 31 | 9 | 18 | 103 | 294 | 540 | 823 | 4583 |
| CDD, Base 18.3°C | 0 | 0 | 0 | 0 | 16 | 56 | 111 | 74 | 6 | 0 | 0 | 0 | 262 |
| Relative Humidity (%) | 77 | 76 | 75 | 68 | 67 | 69 | 72 | 75 | 75 | 72 | 77 | 80 | 74 |
| Wind Speed (m/s) | 6.6 | 6.3 | 6.6 | 6.6 | 6.0 | 5.7 | 4.9 | 4.9 | 5.4 | 5.9 | 6.2 | 6.3 | 5.9 |



Solar Radiation for Flat-Plate Collectors Facing South at a Fixed Tilt (kWh/m²/day), Uncertainty ±9%

| Tilt (°) | | Jan | Feb | Mar | Apr | May | June | July | Aug | Sept | Oct | Nov | Dec | Year |
|--------------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| 0 | Average | 1.8 | 2.7 | 3.7 | 4.6 | 5.6 | 6.2 | 6.2 | 5.3 | 4.0 | 2.8 | 1.7 | 1.4 | 3.8 |
| | Min/Max | 1.5/2.1 | 2.3/3.0 | 3.0/4.3 | 3.9/5.5 | 4.8/6.5 | 5.4/7.3 | 5.3/7.0 | 4.5/6.0 | 3.3/4.7 | 2.3/3.3 | 1.4/2.0 | 1.2/1.7 | 3.7/4.1 |
| Latitude -15 | Average | 2.9 | 3.9 | 4.6 | 5.1 | 5.7 | 6.0 | 6.2 | 5.7 | 4.8 | 3.8 | 2.6 | 2.3 | 4.5 |
| | Min/Max | 2.2/3.6 | 2.9/4.5 | 3.5/5.6 | 4.1/6.3 | 4.9/6.6 | 5.3/7.1 | 5.2/7.1 | 4.7/6.5 | 3.6/5.8 | 3.0/4.7 | 1.7/3.2 | 1.8/2.9 | 4.1/4.9 |
| Latitude | Average | 3.3 | 4.2 | 4.7 | 4.9 | 5.3 | 5.5 | 5.7 | 5.5 | 4.8 | 4.1 | 2.8 | 2.6 | 4.5 |
| | Min/Max | 2.4/4.2 | 3.1/5.0 | 3.5/5.9 | 4.0/6.2 | 4.6/6.2 | 4.8/6.6 | 4.8/6.6 | 4.4/6.3 | 3.5/5.9 | 3.1/5.1 | 1.8/3.6 | 2.0/3.4 | 4.1/4.9 |
| Latitude +15 | Average | 3.6 | 4.4 | 4.7 | 4.6 | 4.7 | 4.8 | 5.0 | 4.9 | 4.6 | 4.1 | 2.9 | 2.8 | 4.3 |
| | Min/Max | 2.5/4.5 | 3.2/5.2 | 3.4/6.0 | 3.8/5.8 | 4.1/5.4 | 4.2/5.6 | 4.2/5.7 | 4.0/5.7 | 3.3/5.7 | 3.0/5.1 | 1.8/3.8 | 2.2/3.7 | 3.9/4.6 |
| 90 | Average | 3.5 | 4.1 | 3.9 | 3.2 | 2.8 | 2.7 | 2.9 | 3.2 | 3.4 | 3.4 | 2.7 | 2.7 | 3.2 |
| | Min/Max | 2.4/4.4 | 2.9/4.9 | 2.7/5.3 | 2.7/3.9 | 2.6/3.2 | 2.5/3.1 | 2.5/3.2 | 2.6/3.6 | 2.4/4.2 | 2.5/4.3 | 1.5/3.5 | 2.1/3.7 | 2.9/3.5 |



Design Battery Bank

- ▶ Power draw of equipment (2.75 A)
- ▶ Temperature
- ▶ Battery lifecycle



Solar Array Design

- ▶ Solar isolation
 - Power output at standard test condition (1000 w/m^2)
 - vs. measured condition ($2.7 \text{ kWh} / \text{m}^2 / \text{day}$)
- ▶ De-rating factors
 - Soil on panels
 - Efficiency of equipment (charger)
 - Age of panels




Other Factors

- ▶ Theft / Vandals – pole height, mounting hardware (RTMC experience)
- ▶ Lightning protection (Electronic Communication)
- ▶ Structural (Structures & Foundations)
- ▶ Cabinet
- ▶ National Electric Code
- ▶ Network Connected Control and Monitoring



KEEP EXCESS CONDUCTOR
TO A MINIMUM USING
SHORTEST ROUTE TO
GROUND ROD

Solar Site Detail











Solar Power Schematic

24 V DC Power only (no Communications)




Solar Power Cabinet (MN 340 - Stripped)

Placement / Shade



Placement / Shade

$$D = \frac{H_0 - H_s}{\sin(\alpha)}$$



Placement / Shade



Challenges

- ▶ Legal / legislative
- ▶ Extreme environmental demands
- ▶ Site accessibility / slopes



Cost Comparison (Installation)

Grid Connected Site

\$28,693

- ▶ Service Cabinet
- ▶ Camera Pole
- ▶ Camera Cabinet
- ▶ Conductor
- ▶ Foundations

Solar Site

\$37,735

- ▶ Cabinet
- ▶ “Solar Hardware”
- ▶ Solar Panels
- ▶ Solar Mount
- ▶ Camera Pole
- ▶ Conductor
- ▶ Foundations



Cost Comparisin (opperating)

| | 6 Batteries | | 8 Batteries | | Grid Connected | |
|------|-------------|---------------|-------------|---------------|----------------|---------------|
| Year | Costs | Present Value | Costs | Present Value | Costs | Present Value |
| 1 | \$ 1,320 | \$ 1,320 | \$ 1,760 | \$ 1,760 | \$ 440 | \$ 440 |
| 2 | | \$ - | | \$ - | \$ 440 | \$ 427 |
| 3 | | \$ - | | \$ - | \$ 440 | \$ 415 |
| 4 | \$ 1,320 | \$ 1,208 | | \$ - | \$ 440 | \$ 403 |
| 5 | | \$ - | \$ 1,760 | \$ 1,564 | \$ 440 | \$ 391 |
| 6 | | \$ - | | \$ - | \$ 440 | \$ 380 |
| 7 | \$ 1,320 | \$ 1,105 | | \$ - | \$ 440 | \$ 368 |
| 8 | | \$ - | | \$ - | \$ 440 | \$ 358 |
| 9 | | \$ - | | \$ - | \$ 440 | \$ 347 |
| | | \$ 3,633 | | \$ 3,324 | | \$ 3,529 |



Lessons Learned / Conclusions

- ▶ Solar industry lead-times
- ▶ Additional safety concerns
 - both sides of switch live
 - high current potential
 - Battery safety
- ▶ Solar Power is a feasible option for SOP problems



Resources

- ▶ NREL
- ▶ PVwatts
- ▶ Solar Power in Building Design by Peter Gevorian

